

The following samples were collected in the JFK Library:

- Atrium
- M04
- M23

Building	RM #			Time
JFK	Outside front ramp	Outside top of stairs	Outside book return	15:31 - 15:36
	Sa1	Sa2	Sa3	
0.3	175461	183827	176392	178560
0.5	9426	10948	9994	10123
1	1130	1177	1230	1179
2.5	644	588	722	651
5	156	153	148	152
10	41	62	29	44
Temp	63.9			
RH	34.3			

Building	RM #			Time
JFK	Atrium by entry to checkout	Atrium by bookshelves	Atrium by middle window	15:37-15:43
	Sa1	Sa2	Sa3	
0.3	56368	56258	56635	56420
0.5	2470	2493	2490	2484
1	233	300	252	262
2.5	163	256	156	192
5	34	70	46	50
10	18	35	19	24
Temp	67.3			
RH	32.2			

Building	RM #			Time
JFK	M04F	M04 R middle	M04C	15:45 - 15:51
	Sa1	Sa2	Sa3	
0.3	50148	53655	53029	52277
0.5	2186	2288	2300	2258
1	171	122	152	148
2.5	130	52	71	84
5	45	9	20	25
10	34	9	14	19
Temp	73.5			
RH	27.9			

Building	RM #			Time
JFK	M23 L of entry	M23 R middle	M23C	15:56 - 16:01
	Sa1	Sa2	Sa3	
0.3	45070	47690	49721	47494
0.5	1925	2020	2215	2053
1	146	138	179	154
2.5	85	80	114	93
5	18	14	34	22
10	7	2	11	7
Temp	74			
RH	27.6			

### Comparables

	Inside	Outside	% diff
µm			
0.3	52064	178560	109.7
0.5	2265	10123	126.9
1	188	1179	145.0
2.5	123	651	136.5
5	32	152	130.2
10	17	44	90.6
Temp	72	64	11.4
RH	29	34	15.9