

JFK Particle Counts 11/02/18

Date 11/02/18

Building	RM #	M23	Time	Building	RM #	M04	Time	Building	RM #	U02	Time
JFK	3 HEPAs running			JFK	2 HEPAs running			JFK	2 HEPAs running		
	Sa1	Sa2	Sa3		Sa1	Sa2	Sa3		Sa1	Sa2	Sa3
	1732	1701	1839		1781	1753	1791		1222	1147	1334
0.3	402	451	407	0.3	289	288	329	0.3	185	228	245
0.5	178	212	234	0.5	82	88	151	0.5	52	101	90
1	187	237	221	1	50	61	141	1	35	100	108
2.5	60	67	40	2.5	28	14	35	2.5	7	28	24
5	24	17	13	5	20	20	35	5	4	21	11
10	72.3		18	10	70.9		25	10	72.5		12
Temp				Temp				Temp			
RH	38.1			RH	40.3			RH	37.9		

Building	RM #	Time	Building	RM #	U02	Time
JFK	Outside Air intake loading dock		Hall	outside		
	Sa1	Sa2		Sa3	U02	
	10595	9312		2747		
0.3	939	917		773		
0.5	302	325		401		
1	208	247		433		
2.5	63	80		111		
5	15	17		54		
10	58.2					
Temp						
RH	53.6					

Building	RM #	Time	Building	RM #	U02	Time
JFK	Outside Air intake loading dock		JFK	Hall		
	Sa1	Sa2		Sa3	U02	
	10595	9312		2747		
0.3	939	917		773		
0.5	302	325		401		
1	208	247		433		
2.5	63	80		111		
5	15	17		54		
10	58.2					
Temp						
RH	53.6					